



AC 038



EX-17-07



Główny Instytut Górnictwa
Jednostka Certyfikująca
Zespół Certyfikacji Wytwarzania
KD „Barbara”
ul. Podleska 72
43-190 Mikołów,
tel. (+48) 32 3246550
fax. (+48) 32 3224931
www.gig.katowice.pl

This certificate and its
schedules may only be
reproduced in its entirety and
without change

Product certification program
no: PCW-ISO/IEC-1b
CODE ICS 13.230

[1]

SUPPLEMENT No 4
to EC-TYPE EXAMINATION CERTIFICATE
KDB 07ATEX055X



[2] Equipment, protective systems and components intended for use in potentially explosive atmospheres
- Directive 94/9/EC

[3] Equipment and protective system:

**Temperature sensors: head sensors, cable sensors,
ambient temperature sensors and high-temperature
sensors.**

[4] Manufacturer:

Limatherm Sensor Sp z o. o

[5] Address:

ul. Tarnowska 1, 34-600 Limanowa, Poland

[6] Changes were introduced to design or construction of component in accordance with the
specification set out in the Schedule attached to this certificate and the documents therein referred
to.

This document shall be held with the original Certificate.

The examination and test results are recorded in confidential report
KDB No. 09.179-3 [T-5940]

[7] Marking:

Ex	I M1 Ex ia I	or
Ex	I M1 Ex ia I	or
Ex	II 1/2 G Ex ia IIC T6*	or
Ex	II 2 G Ex ia IIA T6*	or
Ex	II 1D Ex iaD 20 T85°C*	

[8] Compliance with the Essential Health and Safety Requirements has been assured by
compliance with:

EN 60079-0:2012 + A11:2013	(PN-EN 60079-0:2013-03 + A11:2014-03)
EN 60079-11:2012	(PN-EN 60079-11:2012)
EN 50303:2000	(PN-EN 50303:2004)
EN 60079-26:2007	(PN-EN 60079-26:2007)

[9] The marking will change to:

Ex	I M1 Ex ia I Ma	or
Ex	II 1/2G Ex ia IIC T6-T1 Ga/Gb	or
Ex	II 2G Ex ia IIC T6-T1 Gb	or
Ex	II 1D Ex ia IIIC T85°C Da	or
Ex	II 2G Ex ia IIB T6-T1 Gb	

Specjalista ds. Certyfikacji
Urządzeń Przeciwwybuchowych

dr inż. Michał Górny



KIEROWNIK
Zespołu Certyfikacji Wytwarzania
KD „BARBARA” Mikołów
dr hab. inż. Krzysztof Cybulski, prof. GIG

Date of issue: 09.02.2015
Date of English version: 03.03.2015

[10]

SCHEDULE

[11]

Supplement no 4 to EC-Type Examination Certificate KDB 07ATEX055X

[12]

Description of the variation to the equipment or protective system:

Manufacturer adapted the device to requirements of the standards specified in point 8 hereto, updated the technical documentation. The thermocouple sensors parameters not changed. Was introduced special conditions for safe use as well as for a bottom listed thermometric resistors electrical parameters was updated.

- **head sensors:** I M1 Ex ia I Ma

.	T O P	.	Exi	-	N 1	-	.	.	.	.	.	.	P t 1 0 0	-	.	.	.	.	.	.
single : blank I-3; I-6, I-8, GB-1; GN-1; T-1, SW-1, SW-2, P-1, SWT-1, SWG-1, GWN-5 -40°C ≤ Ta ≤ 60°C, Pi=150mW, Ui=45V, Ii=26mA; -40°C ≤ Ta ≤ 75°C, Pi=100mW, Ui=10V, Ii=10mA; blank SP																				

.	2	T O P	.	Exi	-	N 1	-	.	.	.	.	.	.	P t 1 0 0	-	.	.	.	.	.
double : I-6, I-8, GB-1; GN-1; T-1, SW-2, P-1, SWT-1, SWG-1, GWN-5 -40°C ≤ Ta ≤ 60°C, Pi=150mW, Ui=45V, Ii=26mA; -40°C ≤ Ta ≤ 75°C, Pi=100mW, Ui=10V, Ii=10mA; blank SP																				

.	2	T O P	.	Exi	-	N 1	-	.	.	.	.	.	.	P t 1 0 0	-	.	.	.	.	SP
double: I-3, SW-1 -40°C ≤ Ta ≤ 75°C, Pi=100mW, Ui=10V, Ii=10mA;																				

[10]

SCHEDULE

[11]

Supplement no 4 to EC-Type Examination Certificate KDB 07ATEX055X

[12]

Description of the variation to the equipment or protective system:

[13] **Special conditions for safe use:**

- Temperature class of a sensor depends on the measured temperature. After mounting, it should be checked if temperature of any part doesn't exceed acceptable limits for potentially explosive atmosphere, materials and devices.
- Circuits temperature sensors with double measurement elements should be considered as electrically connected.

